

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**55000-122 Series 65 Conventional Class A1R Heat Detector**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Limited**  
**36 Brookside Road, Havant, Hampshire, PO9 1JR, UK**

and produced in the manufacturing plant:

**Apollo Fire Detectors Limited**  
**36 Brookside Road, Havant, Hampshire, PO9 1JR, UK**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-5:2000/A1:2002** : Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2019-10-09**

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

This certificate was first issued 2019-10-09



Merete Poulsen  
Responsible for evaluation



Allan Laursen  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)

## Annex 1

### EXTENT

**Type:**

55000-122 Series 65 Conventional Class A1R Heat Detector

**Variant:**

55000-122LIM (branded as Limotec)

**Bases:**

45681-200 Series 60/65 Mounting Base  
45681-201 Series 60/65 Diode Mounting Base  
45681-245 Series 65 Relay Mounting Base  
45681-246 Series 65 Auxiliary Relay Mounting Base  
45681-247 Series 65 EOL 12 Volt Mounting Base  
45681-248 Series 65 EOL 24 Volt Mounting Base

**Note:**

1. Meets the requirements of EN54: Part 5 – Class A1R

**Performance**

| Essential characteristics   | Clauses in EN 54-5:2000  | Performance |
|---|--|-------------|
| Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions | 4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2<br>(6.1 only Suffix S det./6.2 only Suffix R det.) | Pass        |
| Operational reliability   | 4.4 to 4.11  | Pass        |
| Tolerance to supply voltage   | 5.7  | Pass        |
| Durability of operational reliability and response delay; temperature resistance                                | 5.9, 5.10  | Pass        |
| Durability of operational reliability; vibration resistance   | 5.14 to 5.17   | Pass        |
| Durability of operational reliability; humidity resistance  | 5.11, 5.12   | Pass        |
| Durability of operational reliability; corrosion resistance   | 5.13   | Pass        |
| Durability of operational reliability; electrical stability   | 5.18   | Pass        |

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)

## Annex 2

**TEST DOCUMENTATION**

| Accredited Laboratory | Report no.                         | Date                          |
|-----------------------|------------------------------------|-------------------------------|
| BRE<br>VdS            | P100476-1001 Issue: 1<br>BMA 00018 | 30 March 2016<br>3 March 2000 |

**TECHNICAL BASIS**

| File Number   | Title  |
|---|--|
| 55000-122<br>45681-200<br>45681-201<br>45681-245<br>45681-246<br>45691-247<br>45681-248 | Build Standard<br>Build Standard<br>Build Standard<br>Build Standard<br>Build Standard<br>Build Standard<br>Build Standard |

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)