



INCERT CERTIFICATE

C-025-1629/a



Issued 13-12-2022
Expiry date 13-12-2028

Replaces C-025-1629
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Intrusion detector
Trademark: OPTEX
Type designation: FLX-A-AM
Software: 1069.3

Placed on the market under the name or trademark of:

Name of the manufacturer: Optex Co. , LTD.
Address: Ogoto Shiga 5-8-12
City: 520-0101 Otsu City
Country: JP

This certificate is granted to:

Name of the certificate holder: Optex Co. , LTD.
Address: Ogoto Shiga 5-8-12
City: 520-0101 Otsu City
Country: JP

Ron Scheepers
Managing director

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.



Remarks and observations

The following conditions are applicable:

Category: PIR detector

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be used in combination with bracket CW-G3.

Factory location:

OPTEX(DONGGUAN) CO.,LTD.

No.2, Jufu Road, Banhu, Huanginang Town,

GuangDong, 523752,

DongGuan City,

P.R.China

Product inspection location:

Nippon Express Nederland

Industrieweg15

Voorschoten

The Netherlands

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication B.V.: P000117865-001-Ver. 1.00, 14 September 2022
- Telefication B.V.: P000263944-001-Ver.1.00, 01 December 2022
- Telefication B.V.: P000117865-002-Ver. 1.00, 14 September 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1+A2

August, 2022

Applied Standards

EN 50130-5	June, 2011
EN 50131-2-2	December, 2021
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|--------------------|
| - Product description: | Intrusion detector |
| - Trademark: | OPTEx |
| - Type designation: | FLX-A-AM |
| - Hardware version: | 0 |
| - Software version: | 1069.3 |